

Certificate

Reg.-No. K 1693 / 01.23

The Certification Body of the MPA Darmstadt
confirms to the manufacturer **Empur Produktions GmbH**
the compliance of the product **Industriepark Nord 1-3**
of the production plant **53567 Buchholz-Mendt**
with the certification program **ZP-445**

5-Layer heating pipe made of PE-RT type II (Dowlex 2388) dimensions 15x1.8 mm, 16 x 2.0 mm, 17x2.0 mm and 20 x 2.0 mm, following to DIN EN ISO 22391-2 sections 4 to 8 and 10 as well as DIN 4726 section 4.4 and 5.4; Operating pressure 6 bar, max. application temperature 70 ° C
GKS GmbH & Co. KG
Industriepark Nord 1-3
53567 Buchholz-Mendt


This certificate is granted based on the results of the continuous inspection by the inspection body of the MPA Darmstadt. The continuous inspection involves:

- Control of the factory production control
- Product testing in accordance to the standard

Therefore the manufacturer is authorized to mark the product with the MPA-CERT-sign according to the terms of MPA Darmstadt for the application of the MPA-CERT-sign.

This certificate is valid for 5 years.

Darmstadt, 12.01.2023


Dr.-Ing. P. Bender
Certification Body




Dipl.-Ing. (FH) Markus Schmitt
Technical responsibility

This document represents the English translation of the original German certificate issued by MPA Darmstadt. Please note that German is the official language of certificates of compliance according to regional building laws and only the German version is legally binding



TECHNISCHE
UNIVERSITÄT
DARMSTADT